



Washington Township / Avon Fire Department

Community Safety and Education Division
7222 East U.S. Highway 36
Avon, IN 46123
(317) 272-2155
www.avonfd.org

REQUIRED INSPECTIONS

Type of Inspection

Explanation of Inspection

Pre-Construction Meeting

After project has been approved we will meet on-site to exchange contact information and discuss important issues.

Construction Site Inspection

Inspection of all underground fire hydrants connections and sprinkler system connections prior to covering them. An inspection of all emergency vehicle access roads will be conducted at this time.

SPRINKLER SYSTEM INSPECTIONS

Sprinkler System, Rough

Inspection of hangers, head placement and conduct hydrostatic test. Piping must be visible for inspection. Fire Sprinkler System contractor must be on-site.

Sprinkler System, Final

All components required are in place and functioning – flow test, horn and strobes, monitoring, FDC, etc. Acceptance testing of all system components shall be required. Aboveground and Underground Hydrostatic Testing Certifications are due at this time. Fire Sprinkler System contractor must be on-site.

Fire Pump

Witness complete pump test per NFPA 20.

FIRE ALARM INSPECTIONS

Fire Alarm System, Rough

Compliance of wire installation and placement of initiating devices. Fire Alarm System contractor must be on-site.

Fire Alarm System, Final

Certificate of Completion paperwork must be completed. System acceptance test will be conducted. Fire Alarm System contractor must be on-site.

KITCHEN RANGEHOOD SYSTEM INSPECTION

Fire Suppression System, Final

Commercial kitchens. Perform acceptance test on all components of fire suppression system. Fire Suppression System contractor must be on-site.

SPRAY BOOTH INSPECTIONS

Fire Suppression System, Final

Spray booths. Perform acceptance test of all fire suppression system components in spray booth. Fire Suppression System contractor must be on-site.

CLEAN AGENT SYSTEM INSPECTION

Clean Agent Fire Suppression System, Final

FM 200, Intergen, Halon or other gas extinguishing systems. Acceptance test will be performed and the installing contractor must be on-site.

KNOX BOX

Install Keys in Knox Box

Provide two (2) master keys for the building Knox Box.

CERTIFICATE OF OCCUPANCY

Pre-Final Inspection

Walk through the entire building approximately one week prior to desired final inspection. We will identify and document all items that must be completed prior to the issuance of a Certificate of Occupancy.

Final Inspection

All items on the list of violations/deficiencies has been completed and the business is ready to open. If any deficiencies remain they will be documented and a re-inspect scheduled.